



Statement of Test Result

2018-06-28

ELSTEEL (PVT) LTD
Spur Road 2
Phase-I Epz
Katunayake, LK

Our Reference: File E207550, Vol 1

Order: 12173436

Project 4788358975

:

Your Reference: EL18-0511

Project Scope: Update file E207550, Vol.2, Sec 1 with environmental rating Type 12 and 2

Dear Mr. Peter Alexeev:

Congratulations! UL's tests of your product(s) has been completed under the above Reference Number and the product was determined to comply with the applicable requirements for Type 2 and 12.

Following tests have been conducted and meet the requirements:

- Drip test
- Atomized water test - Method A
- Gasket test – Tensile strength and elongation
- Gasket oil immersion test

This letter only indicates that the applicable tests have been conducted and meet the requirements. The technical update of the file is still pending. The products must not be considered to be UL certified before the file have been updated and the applicant have received the Notice of Authorization.

Any information and documentation provided to you involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.

Feel free to contact me or any of our Customer Service representatives if you have any questions.

Very truly yours,

Reviewed by:

Heine Lund

Mogens Christensen

Heine Lund
Staff Engineer
UL International Demko A/S

Mogens Christensen
Staff Engineering Associate
UL International Demko A/S

02cba950-8bfb-46eb-8eab-1ee1762061f5